

Erfaringstal for luftskifte pr. time

Skolelokale 3-5 gange pr. time

Kontor 3-8 gange pr. time

Toiletter 5-15 gange pr. time

Antal M³

1.01 Håndbogsbibliotek + 1.02 Depot + 1.03 Mediatek	1498 M ³
2.02 Vi-gør-rum	74 M ³
1.04 Kontor	82 M ³
1.05 Forberedelses	63 M ³
1.06 Wc	11 M ³
1.07 Wc	6 M ³
1: 1.01 + 2.02 + 1.04 + 1.05	1835 M ³
2: 1.06 + 1.07	17 M ³
1: 1835 * 3 gange luftskifte	5505 M ³ /H
2: 17 * 5 gange luftskifte	85 M ³ /H
I alt + 136	5590 M ³ /H
Omregnet til M ³ /S 5590/3600	1,55 M ³ /S
Valg af B-1417 L-2597	